## SITE ACCEPTANCE REPORT

The site acceptance test was carried out from 7th August 2023 to 11th August 2023

As per Performance Guarantee and Demonstration clause, the unit has been tested and 10kg/hr of CO2 is captured in the Absorption Cycle. The readings of absorption cycle are attached in Annexure C

The rich solvent has been tested and results indicate that 10kg/hr of CO2 has been absorbed by the solvent. The calculations of absorption are detailed in Annexure B

The Desorption process has been carried out and readings are attached in Annexure C. The solvent after desorption has been tested and results indicate that the solvent has been regenerated.

From the analysis of solvent has been proved that solvent has regenerated by displacing captured CO2. Additional testing's were carried out after commissioning of plant and modifications were done in the existing unit which are also attached in the following Annexure.

Table 1.1.: CO<sub>2</sub> absorption

Solvent flow Kg/min	CO2 flow in, lpm	CO2 loading (pH 10.2)	CO2 loading (pH 9.8)	CO2 flow in, mol/min	CO2 absorbed
4	108	0.16	0.36	4.6	3.92

Based on pH values w.r.t to the CO2 loading values, the CO2 absorbed is 10.37 kg/h i.e The CO2 absorption is 85%.

Table 1.2.: CO<sub>2</sub> desorption

Solvent Temperature, deg C	Solvent pH in	Solvent pH out	
108	9.49 (0.4 CO2 loading)	10.1 (0.15 CO2 loading)	

Based on pH values and its respective CO2 loading values, it is concluded that the CO2 is desorbed from the solvent.

Asst. Manager

Trilok Corporation, Mumbai

NOTE: A spare Nitrogen heater (EH03) suitable for the process will be supplied by Trilok Corporation to BPCL R&D.

Manager (R&D), Gr. Noida

Bharat petroleum Co. Ltd